



ADDENDUM NO. 1 TO THE BID DOCUMENTS FOR:

**Campus Paving and Drainage Project
Capital Project #24A02**

Date of Addendum: June, 13, 2024

Bid Due Date/Time: June 18, 2024 - 4:00PM Local Time (Unchanged)

Previous Addendums: None

To: Prospective Bidders:

This Addendum forms part of the “Contract Documents” and modifies or clarifies the original “Contract Documents” for this Project dated May 24, 2024. Prospective Bidders **shall** acknowledge receipt of the total number of Addenda issued for this Project in the Bid Documents.

Item 1:

Bid Item B5, “Lower SoCal Edison Vaults”: Has been removed from the scope of the project. These vaults will be treated as a fixed point, and new HMA will be installed up to the existing surface feature. The bidder will treat these vaults as a “Protect in Place” feature.

Bid Item B6, “Lower MCWD Electrical Vaults”: Has been removed from the scope of the project. These vaults will be treated as a fixed point, and new HMA will be installed up to the existing surface feature. The bidder will treat these vaults as a “Protect in Place” feature.

Bid Item B7, “Lower MCWD Communications Vaults”: Has been removed from the scope of the project. These vaults will be treated as a fixed point, and new HMA will be installed up to the existing surface feature. The bidder will treat these vaults as a “Protect in Place” feature.

Item 2:

Bid Item C2, “Supply and Install new 16”x19” DI”: This Bid Item has been modified to be a 16”x16” DI rather than the 16”x19” DI originally called for in the contract documents.

Item 3:

HMA Specifications: In any instance within the contract documents where there is a conflict between AASHTO R35 and Caltrans Standard 39, the provisions of Caltrans Standard 39 shall take precedence and supersede those of AASHTO R35.

Item 4:


Permits: See Town of Mammoth Lakes Encroachment permit, Grading permit, a sample SWPPP and revised project plans at: <https://mcwd.dst.ca.us/mcwd-campus-paving-request-for-bid>.

BID SCHEDULE				CONTRACTORS BID	
Selected	Line Item	Quantity	Unit of Measure	Unit Price	Total Cost
A. SITE PREPARATION					
A1	MOBILIZATION	1	LS		
A2	QUALITY CONTROL PROGRAM	1	LS		
A3	IMPLEMENTATION OF SWPPP (PREPARED BY MCWD)	1	LS		
A. SUB TOTAL:					
B. EXISTING FACILITIES					
B1	LOWER SEWER CLEAN OUTS	3	EACH		
B2	REMOVE EXISTING 16"X19" DI	5	EACH		
B3	LOWER DROP INLETS	2	EACH		
B4	LOWER SEWER MAN HOLES	6	EACH		
B5	LOWER SOCIAL EDISON VAULTS	5	EACH		
B6	LOWER MCWD ELECT. VAULTS	15	EACH	-	-
B7	LOWER MCWD COM. VAULTS	11	EACH	-	-
B8	LOWER MCWD WATER VALVES	10	EACH	-	-
B9	REMOVE EXISTING CONCRETE	11	CY		
B10	REMOVE EXISTING BLOCK STEM WALL	1	LS		
B11	REMOVE EXISTING HYDRONIC PIPING	1	LS		
B. SUB TOTAL:					
C. NEW FACILITIES					
C1	REMOVE & REPLACE PIPE WITH 6" HDPE	129	LF		
C2	SUPPLY & INSTALL NEW 16"X16" DI	7	EACH		
C3	INSTALL NEW 24" DIA GRAVITY DI	1	EACH		
C4	INSTALL NEW 36" DIA GRAVITY DI	1	EACH		
C5	INSTALL NEW 8" HDPE PIPE	176	LF		
C6	INSTALL NEW 36" DRYWELL DI	6	LS		
C7	INSTALL CONCRETE ADA RAMP (ENGINEERING BUILDING)	1	LS		
C8	INSTALL ADA TRUNKATED DOME PAVERS	120	SF		
C. SUB TOTAL:					
D. SITE WORK					
D1	SAW CUT ASPHALT	175	LF		
D2	PULVERIZE EXISTING HMA	181,189	SF		
D3	ROTOMILL	7,771	SF		
D4	EARTHWORK	1	LS		
D5	INSTALL 4" HMA	4,567	TON		
D6	SUPPLY & INSTALL 6" OF REINFORCED CONCRETE	8	CY		
D7	CRACK SEAL	1	LS		
D8	SLURRY SEAL	36,660	SF		
D9	INSTALL SHOULDER BACKING	2748	LF		
D10	T-GRIND & ROTOMILL EXISTING HMA	235	LF		
D11	STRIPING AND PAVEMENT MARKINGS	1	LS		
D12	INSTALL STOP SIGN AND ADA PARKING SIGNS	4	EACH		
D. SUB TOTAL:					
TOTAL:					
				CONTRACTORS BID	
Selected	Line Item	Quantity	Unit of Measure	Unit Price	Total Cost
ALTERNATES					
ALT-1	CRACK SEAL	1	LS		
ALT-2	SLURRY SEAL	14,410	SF		
ALTERNATE SUB TOTAL:					
BIDDER'S GRAND TOTAL:					

End of Addendum 1

Dated: June 13 2024

Mammoth Community Water District

By: 

Nolan Ferguson
Staff Engineer